

Technical Appendix 1.5: Eskdalemuir Seismic Impact Study

M74 West Wind Farm, Eskdalemuir Seismic Array Considerations

Updated Report on Seismic Budget Requirements, Seismic Impact Limits and Queue Scenarios

Client: Renewco Power

31/07/2024

Document number: REN-104 Updated M74 West Report v7



Xi Engineering Consultants, CodeBase, Argyle House, 3 Lady Lawson Street, Edinburgh, EH3 9DR, United Kingdom.
T: +44 (0)131 290 2250, xiengineering.com, Company no. SC386913

Document Summary


The detection capabilities of the Eskdalemuir Seismic Array are protected from seismic noise generated by wind turbines using a cumulative noise budget for all turbines built within 50 km of the array. A Seismic Impact Limit (SIL) for any new wind turbines has been proposed to maximise the installable wind energy capacity of the Southern Uplands while continuing to protect the detection capabilities of the Eskdalemuir seismic array. A SIL between $0.00836\text{nm}\cdot\text{MW}^{-0.5}$ and $0.00528\text{nm}\cdot\text{MW}^{-0.5}$ will likely be set for all new wind turbines installing Eskdalemuir Consultation Zone.

An analysis was carried out of the 22 turbines in the proposed M74 West Wind Farm to determine the seismic budget requirement for the site and whether seismic levels exceed those specified by the SIL. For the proposed 6.3 MW turbines at M74 West Wind Farm the permitted power seismic value (PSV) for a machine of this power output is 0.021009 nm for a 1 GW SIL limit, and 0.013278 nm for a 2.5 GW SIL Limit. At the time of writing the candidate turbine for M74 West Wind Farm is not known and as such several turbines have been analysed. The seismic output of the site was modelled using publicly available data, a total of eighteen scenarios were run based on *refined Phase 4 'AIFCL-101-Phase4-Rev-v13*.

The seismic budget requirement for M74 West Wind Farm ranges from 0.017515 nm down to 0.004615nm, depending on which make of turbine is deployed. Were background noise to be removed, the seismic budget requirement would be substantially reduced. To remove background noise, a baseline measurement of noise on the site prior to installation of turbines is recommended, from which accurate data can be provided for later stage calculations of actual seismic budget requirements of the operational site.

Due to the relatively large distance (~43 km) of M74 West Wind Farm from the seismic array, the turbine size and the 6.3 MW rated capacity there is very low risk of breaching the SIL and therefore the turbines would not require mitigation to be installed.

Five queue scenarios with 1.0 GW, 2.0 GW or 2.5 GW SILs were considered. For a SIL of 1.0 GW, the only scenario where M74 West Wind Farm falls within the 0.336 nm budget is Scenario 3 (All wind farms except Faw Side, Scoop Hill and Teviot). For a SIL of 2.0 GW, M74 West Wind Farm falls within the budget for all scenarios except for Scenario 5 (All wind farms included). For a SIL of 2.5 GW, M74 West Wind Farm falls within the budget for all scenarios.



Action	Name	Date	Version	Amendment
Originator	D. Lamb	17/07/2024	v1	Originator
Editing	M. Chung	18/07/2024	v2	Results
Review	R. Horton	25/07/2024	v3	Review
Editing	M. Chung	29/07/2024	v4	Queue Scenarios
Review	R. Horton	30/07/2024	v5	Review
Review	M. Chung	31/07/2024	v6	Review
Review	Dr MP Buckingham	31/07/2024	V7	Review

Matters relating to this document should be directed to:	
Dr Mark-Paul Buckingham	E: mp@xiengineering.com
Managing Director	T: 0131 290 2257
	M: 07747 038 764
Dr Brett Marmo	E: brettmarmo@xiengineering.com
Technical Director	T: 0131 290 2249
Principal contacts at client's organisation	
Maeve Fryday	maeve.fryday@renewcopower.com
Senior Developer Onshore Wind	07749490015

Contents

1.	Introduction	6
2.	Background to Eskdalemuir.....	7
2.1.	2019-2022 Scottish Government Commissioned Xi Engineering Studies	8
2.2.	Eskdalemuir Working Group (EWG) scope of works for 2023 to deliver additional capacity for the region.....	8
2.3.	Incorporation of MoD Technical Experts Feedback.....	9
3.	Definitions	10
4.	Technical Background	10
4.1.	Relationship between distance and seismic impact	10
4.2.	Derivation of the Seismic Impact Limit (SIL).....	10
4.3.	Power Seismic Value for a Given Turbine.....	11
4.4.	Turbine Mitigation Ratio for a Given Turbine.....	11
5.	Methodology	12
5.1.	Candidate Machine	12
5.2.	Wind farm specifications	12
5.3.	Site details	12
5.4.	Budget and SIL Scenarios Assessed.....	13
5.5.	Background Noise Removal	14
5.6.	Queue Scenarios Assessed	15
6.	Results.....	16
6.1.	The seismic budget requirements for M74 West Wind Farm	16
6.2.	Seismic Impact Limit Turbine Mitigation Ratio Results.....	19
6.1.	Mitigation	21
6.2.	Queue Scenario Results.....	22
6.2.1.	Scenario 1 – All wind farms included except Faw Side.....	22
6.2.2.	Scenario 2 – All wind farms included except Faw Side and Scoop Hill	23
6.2.3.	Scenario 3 – All wind farms except Faw Side, Scoop Hill and Teviot.....	24
6.2.4.	Scenario 4 – All wind farms except Faw Side and those in Scoping	25
6.2.1.	Scenario 5 – All wind farms included	26
7.	Discussion	27

7.1.	Modelled Budget Requirements	27
7.2.	Modelled SIL Requirements.....	27
7.1.	Queue Scenarios	27
8.	Conclusion.....	28
9.	Reference Documents.....	29

1. Introduction

The Eskdalemuir Seismic Array (EKA) is operated by the Ministry of Defence (MoD) and is used to detect ground vibration (seismic waves) caused by nuclear weapons tests. Wind turbines in the Eskdalemuir region also create seismic waves which reduce EKA’s detection capabilities. To protect the detection capabilities of EKA, a 50 km consultation zone has been placed around the array and the cumulative impact of all wind turbines built within the zone must not exceed a seismic vibration budget of 0.336 nm.

The Scottish Government seek to maximise the installable wind energy capacity while continuing to protect the detection capability of EKA. Based on the results of the recent draft Onshore Wind Policy Statement consultation, as well as the multi-phased technical work carried out by Xi Engineering Consultants to inform the statement, the Scottish Government are considering the establishment of a *Seismic Impact Limit* (SIL) for new turbines placed in the consultation zone. The SIL is an upper limit to seismic impact on EKA that any one turbine is responsible for relative to its electrical generation capacity. Based on The Scottish Government’s analysis provided by Xi, the SIL will likely be set between **0.00836nm·MW^{0.5}** and **0.00528nm·MW^{0.5}**. Additional wind turbines will need to demonstrate that for their given capacity they do not breach the SIL.

This report assumes a working understanding of considerations within the EKA. For further details, please see the publicly available documents listed in reference section 9.

Renewco Power wish to develop the M74 West Wind Farm site within the Eskdalemuir Consultation Zone. This environmental impact study assesses the vibration impact of the proposed M74 West Wind Farm on the MoD’s Eskdalemuir Seismic Array. The M74 West site represents 22 wind turbines with a proposed rotor diameter of 175 m and 200 m tip height (see Table 2)

This report examines;

1. The seismic budget requirements for M74 West Wind Farm
2. If any/all are close enough to the EKA that they breach the SIL and would require seismic mitigation. In this case, determining what degree of mitigation would be required to reduce their impact below the SIL.
3. Five queue scenarios with 1.0 GW, 2.0 GW or 2.5 GW SILs

2. Background to Eskdalemuir

The Eskdalemuir Seismic Array is a seismological monitoring station in Dumfries and Galloway which forms part of the UK's obligations under the Comprehensive Test Ban Treaty. The array's operation can be compromised by excessive seismic noise in the vicinity, which can be produced by wind turbines operating around the array. A brief explanatory video about the global network of seismic sensors operated by the Comprehensive Test Ban Treaty Organisation (CTBTO) can be found at;

[Video on Seismic Measurement by CTBTO](#)

In May 2005, Scottish Ministers and the Ministry of Defence (MoD) issued a technical site direction with a safeguarding map to relevant planning authorities in England and Scotland as well as Scottish Ministers. This direction advised that any sites within 50km of the array would require consultation with MoD before determination. This 50km radius is often referred to as the 'consultation zone'. Within the consultation zone there is an existing hard no-build area at a radius of 10km from the array – any applications for windfarms within 10km will be objected to by MoD due to the unacceptable impact they would have on the array.

In 2005, a report by Styles recommended a threshold (commonly referred to as the "noise budget") of 0.336 nm of seismic noise disturbance would prevent the array's operation being comprised. Exceeding the 0.336 nm threshold would compromise the array's detection capabilities.

This was followed by the 2014 work undertaken by Xi Engineering Consultants on behalf of the Eskdalemuir Working Group, which developed a purposefully conservative algorithm and associated spreadsheet tool enabling the MoD to manage this seismic ground vibration threshold and thereby safeguard the detection capabilities of the array. The adoption of this 2014 Xi Algorithm allowed in excess of 1.1GW onshore wind development to proceed.

The 0.336nm budget was issued on a first come, first served basis and no project has been allocated budget since January 2018. The MoD's position is that, at present, the threshold of 0.336nm has been reached when using the 2014 Xi Engineering Consultants conservative spreadsheet to calculate the cumulative impact of Wind Turbines on the Eskdalemuir seismic array. As this is the only tool the MoD has available it is objecting to all applications to preserve the array's detection capabilities. Any additional applications received subsequent to January 2018 were added to a 'waiting list' for future MoD approval. The current waiting list based on publicly available data corresponds to approximately 2.5GW of potential onshore wind turbine development. These potential developments would have a significant impact on the 12GW targeted by The Scottish Government by 2030.

2.1. 2019-2022 Scottish Government Commissioned Xi Engineering Studies

Between 2019 and 2022 the Scottish Government commissioned Xi Engineering Consultants to deliver a series of technical evaluations and studies. These studies followed a phased approach (Phase 1 through Phase 5) to investigate the potential additional capacity that may be made available were the 2014 algorithm to be revised. These studies confirmed that the algorithm currently used by the MoD to calculate the budget takes a conservative approach and, by design, over-estimates the seismic contribution of each wind turbine.

The Scottish Government has engaged with MoD to seek the MoD's approval of data collected and are seeking agreement that the MoD will adopt this evidence-based approach and adjust the calculation for budget utilisation.

Unlocking potential capacity whilst safeguarding the array has become the task of the reformed Eskdalemuir Working Group (EWG) with the Scottish Government taking role of secretariat and recognises that:

- Safeguarding of the array lies within the MoD policy remit.
- Maximisation of renewable energy deployment lies within the Scottish Government policy remit.

2.2. Eskdalemuir Working Group (EWG) scope of works for 2023 to deliver additional capacity for the region.

A draft scope of works has been issued for the Eskdalemuir Working Group (EWG) to produce guidance and is targeting 2023 for delivery. *

The following is a direct excerpt from the Draft Scope of works.

Given current demands on resource for Scottish Government and Ministry of Defence, we suggest a preliminary timeframe of Q4 2023 for finalisation of this guidance.

The document reiterates the MoD referenced section from the ONWPS (2.51.2)

Unlocking potential capacity whilst safeguarding the array will require decisive and meaningful action from the Scottish Government and UK Government. To do so, we must recognise:

- *Safeguarding of the array lies within the MoD policy remit.*
- *Maximisation of renewable energy deployment lies within the Scottish Government policy remit.*

The Draft scope of works for the Eskdalemuir working Group puts forward Proposed Approach(es) specifically.

Following these conversations and reflecting on the results of the recent draft Onshore Wind Policy Statement consultation, as well as the multi-phased technical work, the Scottish Government are minded pursuing the following approaches:

1. Establishing a Seismic Impact Limit for Eskdalemuir Seismic Array and the consultation zone

In order to secure a minimum additional capacity of 1 GW within this zone and encourage the use of turbines with the lowest seismic impact, the Scottish Government would require that any proposal yet to be determined must limit the seismic impact of each individual turbine within the consultation zone to $0.00836 \text{ nm.MW}^{0.5*}$ and ensuring the 0.336 nm threshold is not exceeded.

**This limit is based on calculations undertaken by Xi Engineering on behalf of the Scottish Government and may be subject to slight variation during formal signoff process by MoD.*

2. Deployment Maximisation Zone at the Eskdalemuir Seismic Array

To aid in protection of the array, in addition to maximising potential for onshore wind deployment in areas with lesser impact on the array, we would replace the existing 10km exclusion zone with a 15 km exclusion zone. This means that no turbine could be constructed within a 15 km radius of the Eskdalemuir Seismic Array.

**The revised dates are currently under consideration by the Eskdalemuir Working Group (EWG) – July 2024*

2.3. Incorporation of MoD Technical Experts Feedback

Following the MoD subject matter expert’s review of the Phase 4 and Phase 5 work packages released in 2022 refinements to the mathematical analysis used to confirm the ‘headroom’ within the 0.336 nm budget were undertaken. As there was a minor change in the headroom and the Seismic Impact Limit (SIL) is calculated based on the available headroom, Phase 5 was also recalculated based on the refined revisions. For details of the refinement and revision please see section 9.

3. Definitions

In this report, the following nomenclature in Table 1 is employed for clarity:

Acronym	Definition	Notes
SIL	Seismic Impact Limit	Constant $0.00836 \text{ nm.MW}^{0.5}$ for 1 GW capacity.
PSV	Power Seismic Value	The permitted seismic impact of a turbine based on its power output. (Equation 1)
TMR	Turbine Mitigation Ratio	Ratio defining if mitigation is required for a turbine. $\text{TMR} < 1$ requires mitigation. (Equation 2). Turbine with $\text{TMR} \geq 1$ require no mitigation and have TMR listed as “not applicable” (N/A).

Table 1 Summary of acronyms used in this report relating to Seismic Impact Limit.

4. Technical Background

4.1. Relationship between distance and seismic impact

The amplitude of a seismic wave decreases rapidly with distance. This means that turbines built close to the EKA have a far greater impact on the seismic array and consume considerably more seismic budget. A single turbine placed on the border of the 10 km exclusion zone would have the equivalent seismic budget requirement equivalent to approximately 2,000 of the same turbines placed at a distance of 50 km (this calculation is model specific and may vary due to the make and model of the turbine). The installable capacity within the consultation zone can be maximised by avoiding placing turbines close to the EKA. To this end, an upper limit SIL, has been proposed to determine the impact that any single turbine has on the EKA. Given the impact reduces rapidly with distance, the SIL will only affect wind turbines close to the EKA (e.g. within ~20 km).

4.2. Derivation of the Seismic Impact Limit (SIL)

To quantify an appropriate value for the SIL it is necessary to determine the amount of the 0.336 nm seismic budget that remains in the consultation zone and to have a minimum target of installable wind energy capacity to which the remaining budget will be converted. The Phase 5 study for the Scottish Government and the EWG calculates the remaining Eskdalemuir Consultation Zone budget, where sites that are operating adopt an ‘as measured’ seismic vibration level. For all sites up to and including Scotston Bank, the cumulative seismic impact of all wind farms in the queue is 0.20756 nm . This is significantly below the budget threshold of 0.336 nm . Given that the impact of farms adds in quadrature, the head-room within the budget is 0.26422 nm :

$$\sqrt{0.336^2 - 0.20756^2} = 0.26422$$

The Scottish Government required a SIL level be derived that would result in the consumption of this 0.22560 nm and would produce no less than an additional 1 GW of wind turbine capacity. Definition of the SIL as documented in the Phase 5 report: *A Seismic Impact Limit for any given turbine is the arrival amplitude at EKA of the groundwave generated by the given turbine (in nanometres) relative to output power (in megawatts)*. The SIL level for a minimum installable capacity 1 GW was found to be 0.00836 nm.MW^{-0.5}.

In summary, SIL assumes that the seismic power produced by wind turbines has a close to linear relationship with their output power.

To take account of this near linear relationship to the physical size of a turbine, the Seismic Impact Limit is specific to a turbine’s maximum power output.

Definition of the SIL is documented in the Phase 5 report: *A Seismic Impact Limit for any given turbine is the arrival amplitude at EKA of the groundwave generated by the given turbine (in nanometres) relative to output power (in megawatts)*.

4.3. Power Seismic Value for a Given Turbine

The seismic impact that any one turbine is permitted to produce is referred to as the turbine’s Power Seismic Value (PSV), which scales for its rated power according to equation 1:

$$PSV = SIL \cdot \sqrt{Power} \quad (1)$$

where SIL is 0.00836 nm.MW^{-0.5} and Power is the turbine’s rated power in MW.

4.4. Turbine Mitigation Ratio for a Given Turbine

If the seismic impact of a turbine exceeds its PSV, then it would require some form of mitigation. The level of mitigation required to ensure a turbine is compliant is given by the Turbine Mitigation Ratio (TMR):

$$TMR = \frac{PSV}{Turbine\ Amplitude\ at\ EKA} \quad (2)$$

For Turbine Mitigation Ratios greater than 1, no mitigation is required while numbers below 1 require mitigation consistent with the ratio.

5. Methodology

5.1. Candidate Machine

At this stage of development, the specific candidate machine is not fixed.

5.2. Wind farm specifications

M74 West Wind Farm is proposed to consist of 22 turbines each proposed to be 6.3 MW, providing a maximum capacity of 138.6 MW (see Table 2). As the current layout of the proposed M74 West Wind Farm is between 41.1 km and 44.6 m from the Eskdalemuir Seismic Array (EKA) it is likely to be subject to a Seismic Impact Limit, if adopted. Based on the proposed 6.3 MW turbines to be deployed at M74 West Wind Farm, the Power Seismic Value (PSV) of each turbine was calculated using equation 1. As all turbines at M74 West Wind Farm are proposed to have the same 6.3 MW power output, the PSV for each turbine is between 0.021009 nm for a 1GW SIL limit, and 0.013278 nm for a 2.5 GW SIL Limit.

5.3. Site details

The proposed M74 West Wind Farm consists of 22 Turbines with a tip height of 200 m. The nearest turbine is 41.1 km from the Eskdalemuir Seismic Array. Specific Turbine locations and dimensions are shown in Table 2.

Turbine ID	Eastings	Northings	Range (km)	Hub Height (m)	Rotor diameter (m)	Power (MW)
1	289226	628279	43.97	112.5	175.0	6.3
2	289653	628010	43.46	112.5	175.0	6.3
3	289983	627700	43.02	112.5	175.0	6.3
4	288602	627840	44.27	112.5	175.0	6.3
5	289004	627578	43.79	112.5	175.0	6.3
6	289398	627296	43.30	112.5	175.0	6.3
7	289907	627124	42.78	112.5	175.0	6.3
8	290496	626904	42.16	112.5	175.0	6.3
9	291024	626883	41.70	112.5	175.0	6.3
10	287981	627375	44.56	112.5	175.0	6.3
11	288776	626791	43.58	112.5	175.0	6.3
12	289303	626583	43.02	112.5	175.0	6.3
13	289747	626380	42.54	112.5	175.0	6.3
14	290183	626235	42.09	112.5	175.0	6.3
15	290787	626292	41.60	112.5	175.0	6.3
16	291256	626117	41.10	112.5	175.0	6.3
17	287557	626728	44.61	112.5	175.0	6.3
18	287965	626424	44.11	112.5	175.0	6.3
19	288535	626071	43.44	112.5	175.0	6.3
20	289421	625632	42.45	112.5	175.0	6.3
21	290002	625678	41.97	112.5	175.0	6.3
22	290089	625121	41.62	112.5	175.0	6.3

Table 2 M74 West Wind Farm Turbine Locations in Easting and Northing

5.4. Budget and SIL Scenarios Assessed

In order to contextualise the implications and demonstrate potential required budget levels and the impact of the SIL, several scenarios have been assessed for different machines. The turbine coordinates and turbine options were coded into MatLab, and calculations were performed to determine budget levels in line with the mathematical approaches in the reports ‘SGV 203 Technical report v12.pdf’ and refined Phase 4 ‘AIFCL-101-Phase4-Rev-v13’: Field audit of Selected sites within the EKA Consultation Zone to support Government Policy Decisions’.

Seismic measurements of wind turbines include ambient seismic noise. This noise is not attributed to the wind turbines themselves, rather it is produced by a combination of natural and anthropogenic sources. It has been proposed that a background noise measurement could be conducted before wind farms are built and then a subsequent measurement be

conducted once the farm is operational. Budget Scenarios 9 – 16 & 18 (see below) have been included in the analysis to demonstrate the effect of performing before and after measurement in order to remove background noise. The Budget scenarios modelled are as follows;

- | | |
|--|---|
| 1. Standard EKA algorithm | Using the Current MoD ‘worst case’ algorithm. |
| 2. Siemens | Using Phase 4 published data |
| 3. Senvion | Using Phase 4 published data |
| 4. Vestas | Using Phase 4 published data |
| 5. GE | Using Phase 4 published data |
| 6. Nordex | Using Phase 4 published data |
| 7. Enercon | Using Phase 4 published data |
| 8. Gamesa | Using Phase 4 published data |
| 9. Standard EKA algorithm background removed | See Background noise removal section |
| 10. Siemens background removed | See Background noise removal section |
| 11. Senvion background removed | See Background noise removal section |
| 12. Vestas background removed | See Background noise removal section |
| 13. GE background removed | See Background noise removal section |
| 14. Nordex background removed | See Background noise removal section |
| 15. Enercon background removed | See Background noise removal section |
| 16. Gamesa background removed | See Background noise removal section |
| 17. Siemens Gamesa 155 | Data from Manufacturer measured by Xi |
| 18. SG155 Background removed | See Background noise removal section |

5.5. Background Noise Removal

The background noise could then be subtracted from the operational noise giving a truer value of the contribution of the wind farm to seismicity. This approach is common in acoustic measurements of wind farms. To illustrate the effect that such a measurement campaign may have, tables have been provided where the noise floor has been removed from the algorithms such that the seismic contribution of the wind turbines only come from blade pass and structural resonances. This is very much a best-case scenario and is provided for illustrative purposes only. The authors note that the approach of removing all background noise from the algorithm is contrary to the precautionary approach used to design the 2014 EKA algorithm and that it is likely that some turbines generate noise which exists below the noise floor. Working through real world empirical assessments of this will provide further understanding of how close to this best-case scenario results will be. It will also inform the possible development of a methodology which will not penalise a wind turbine for noise which is not attributable to the wind turbine itself.

5.6.Queue Scenarios Assessed

The following queue scenarios were assessed for their impact on budget for M74 West Wind Farm:

1. Scenario 1 - All wind farms included except Faw Side
2. Scenario 2 - All wind farms included except Faw Side and Scoop Hill
3. Scenario 3 - All wind farms included except Faw Side, Scoop Hill and Teviot
4. Scenario 4 – All wind farms included except Faw Side and those in Scoping
5. Scenario 5 – All wind farms included (this is in keeping with the Phase 4 work)

For M74 West Wind Farm, the manufacturer and model of the Turbines are unknown and so the worst-case model was used to assess queue scenarios. In this case the worst-case model utilised was the Vestas model.

6. Results

6.1.The seismic budget requirements for M74 West Wind Farm

The following tables (Table 3 & Table 4) show the seismic budget levels of the Wind Farm as a whole site using the various potential turbine options, with and without background noise, respectively. The seismic budget levels for individual turbines are listed in Table 5 and Table 6 show the seismic budget levels for each individual turbine at the Wind Farm using the various potential turbine options, with and without background noise, respectively. Table 7 shows the TMR against a Scottish Government minimum 1 GW deployment for various turbine types. Table 8 shows the TMR against a Scottish Government maximum 2.5 GW deployment for various turbine types.

Standard EKA Algorithm (nm)	Siemens (nm)	Senvion (nm)	Vestas (nm)	GE (nm)	Nordex (nm)	Enercon (nm)	Gamesa (nm)	SG155 (nm)
0.017515	0.011460	0.007878	0.012654	0.012140	0.009223	0.008269	0.017074	0.004615

Table 3 Seismic results of 8 scenarios modelled using Phase 4 data plus SG155 (all results are in nm).

Standard EKA Algorithm No Background (nm)	Siemens No Background (nm)	Senvion No Background (nm)	Vestas No Background (nm)	GE No Background (nm)	Nordex No Background (nm)	Enercon No Background (nm)	Gamesa No Background (nm)	SG155 No Background (nm)
0.016085	0.009292	0.004574	0.008733	0.010243	0.006097	0.004526	0.011496	0.002549

Table 4 Seismic results of 8 scenarios modelled using Phase 4 data without background noise plus SG155 (all results are in nm).



Turbine No	Standard EKA Algorithm (nm)	Siemens (nm)	Senvion (nm)	Vestas (nm)	GE (nm)	Nordex (nm)	Enercon (nm)	Gamesa (nm)	SG155 (nm)
1	0.003381	0.002225	0.001528	0.002464	0.002345	0.001794	0.001601	0.003324	0.000890
2	0.003538	0.002323	0.001595	0.002568	0.002453	0.001871	0.001673	0.003466	0.000932
3	0.003682	0.002412	0.001658	0.002665	0.002553	0.001942	0.001739	0.003596	0.000970
4	0.003291	0.002169	0.001489	0.002403	0.002283	0.001750	0.001560	0.003243	0.000867
5	0.003435	0.002259	0.001551	0.002500	0.002382	0.001821	0.001626	0.003373	0.000905
6	0.003588	0.002354	0.001617	0.002602	0.002488	0.001896	0.001696	0.003511	0.000945
7	0.003762	0.002462	0.001692	0.002718	0.002608	0.001981	0.001776	0.003667	0.000991
8	0.003980	0.002596	0.001786	0.002862	0.002758	0.002087	0.001876	0.003862	0.001049
9	0.004151	0.002702	0.001860	0.002976	0.002875	0.002171	0.001954	0.004016	0.001094
10	0.003205	0.002116	0.001451	0.002346	0.002223	0.001707	0.001521	0.003165	0.000844
11	0.003499	0.002298	0.001579	0.002542	0.002426	0.001852	0.001655	0.003430	0.000921
12	0.003680	0.002411	0.001657	0.002663	0.002551	0.001941	0.001738	0.003594	0.000969
13	0.003846	0.002513	0.001728	0.002774	0.002666	0.002022	0.001814	0.003743	0.001013
14	0.004007	0.002613	0.001798	0.002880	0.002776	0.002100	0.001888	0.003887	0.001056
15	0.004191	0.002726	0.001877	0.003002	0.002903	0.002190	0.001972	0.004051	0.001105
16	0.004386	0.002846	0.001960	0.003131	0.003036	0.002284	0.002062	0.004224	0.001157
17	0.003191	0.002107	0.001445	0.002336	0.002214	0.001701	0.001514	0.003152	0.000841
18	0.003338	0.002199	0.001509	0.002435	0.002315	0.001773	0.001582	0.003285	0.000879
19	0.003545	0.002327	0.001599	0.002573	0.002458	0.001875	0.001677	0.003472	0.000933
20	0.003877	0.002532	0.001742	0.002794	0.002687	0.002037	0.001828	0.003770	0.001021
21	0.004052	0.002640	0.001817	0.002910	0.002807	0.002122	0.001909	0.003927	0.001068
22	0.004183	0.002721	0.001873	0.002997	0.002897	0.002186	0.001969	0.004044	0.001103

Table 5 Individual seismic Budget calculations for M74 West Wind Farm

Turbine No	Standard EKA Algorithm No Background (nm)	Siemens No Background (nm)	Senvion No Background (nm)	Vestas No Background (nm)	GE No Background (nm)	Nordex No Background (nm)	Enercon No Background (nm)	Gamesa No Background (nm)	SG155 No Background (nm)
1	0.003102	0.001805	0.000886	0.001707	0.001975	0.001190	0.000873	0.002248	0.000486
2	0.003247	0.001884	0.000926	0.001777	0.002068	0.001240	0.000914	0.002339	0.000511
3	0.003381	0.001956	0.000962	0.001841	0.002153	0.001285	0.000951	0.002423	0.000534
4	0.003019	0.001760	0.000864	0.001667	0.001922	0.001162	0.000850	0.002195	0.000472
5	0.003152	0.001833	0.000900	0.001731	0.002007	0.001207	0.000887	0.002280	0.000494
6	0.003294	0.001909	0.000939	0.001799	0.002098	0.001255	0.000927	0.002368	0.000519
7	0.003455	0.001996	0.000983	0.001876	0.002201	0.001310	0.000972	0.002469	0.000547
8	0.003657	0.002104	0.001037	0.001971	0.002329	0.001377	0.001029	0.002594	0.000583
9	0.003816	0.002189	0.001080	0.002046	0.002430	0.001430	0.001073	0.002692	0.000611
10	0.002939	0.001717	0.000842	0.001629	0.001871	0.001135	0.000828	0.002145	0.000458
11	0.003211	0.001864	0.000916	0.001760	0.002045	0.001227	0.000904	0.002317	0.000504
12	0.003379	0.001955	0.000962	0.001840	0.002152	0.001284	0.000951	0.002422	0.000534
13	0.003533	0.002038	0.001004	0.001913	0.002250	0.001336	0.000994	0.002518	0.000561
14	0.003682	0.002118	0.001044	0.001983	0.002345	0.001385	0.001036	0.002610	0.000587
15	0.003853	0.002209	0.001090	0.002063	0.002453	0.001442	0.001084	0.002715	0.000618
16	0.004033	0.002305	0.001138	0.002148	0.002567	0.001502	0.001135	0.002825	0.000651
17	0.002926	0.001710	0.000838	0.001623	0.001863	0.001131	0.000824	0.002137	0.000456
18	0.003062	0.001784	0.000876	0.001688	0.001950	0.001177	0.000862	0.002223	0.000479
19	0.003254	0.001887	0.000928	0.001780	0.002072	0.001242	0.000916	0.002344	0.000512
20	0.003561	0.002053	0.001011	0.001926	0.002268	0.001345	0.001002	0.002535	0.000566
21	0.003723	0.002140	0.001055	0.002002	0.002371	0.001399	0.001047	0.002636	0.000595
22	0.003845	0.002205	0.001088	0.002060	0.002448	0.001440	0.001082	0.002710	0.000617

Table 6 Individual seismic Budget requirements without background noise for M74 West Wind Farm.



6.2. Seismic Impact Limit Turbine Mitigation Ratio Results

WTG No	PSV (nm)	With Background Noise										Without Background Noise									
		Standard EKA TMR	Siemens TMR	Senvion TMR	Vestas TMR	GE TMR	Nordex TMR	Enercon TMR	Gamesa TMR	SG155 TMR	Standard EKA TMR	Siemens TMR	Senvion TMR	Vestas TMR	GE TMR	Nordex TMR	Enercon TMR	Gamesa TMR	SG155 TMR		
1	0.021009	6.214	9.441	13.752	8.527	8.959	11.710	13.119	6.320	23.597	6.773	11.637	23.702	12.305	10.636	17.648	24.056	9.346	43.253		
2	0.021009	5.939	9.045	13.168	8.180	8.564	11.228	12.556	6.062	22.552	6.470	11.152	22.687	11.824	10.159	16.949	22.988	8.980	41.138		
3	0.021009	5.705	8.709	12.672	7.884	8.229	10.818	12.078	5.842	21.663	6.213	10.740	21.828	11.414	9.756	16.353	22.082	8.669	39.341		
4	0.021009	6.384	9.685	14.112	8.741	9.203	12.007	13.467	6.479	24.241	6.960	11.936	24.328	12.601	10.932	18.079	24.715	9.570	44.557		
5	0.021009	6.116	9.300	13.544	8.404	8.818	11.538	12.919	6.228	23.225	6.665	11.464	23.340	12.134	10.466	17.399	23.675	9.215	42.499		
6	0.021009	5.856	8.926	12.992	8.075	8.445	11.083	12.386	5.984	22.236	6.379	11.005	22.382	11.678	10.016	16.737	22.666	8.870	40.499		
7	0.021009	5.584	8.534	12.415	7.730	8.055	10.605	11.829	5.728	21.202	6.080	10.525	21.382	11.200	9.547	16.043	21.612	8.508	38.409		
8	0.021009	5.279	8.093	11.764	7.340	7.618	10.066	11.201	5.439	20.034	5.745	9.984	20.257	10.658	9.021	15.258	20.424	8.098	36.053		
9	0.021009	5.061	7.776	11.298	7.060	7.306	9.679	10.750	5.232	19.196	5.506	9.596	19.453	10.269	8.646	14.693	19.573	7.803	34.368		
10	0.021009	6.556	9.930	14.475	8.956	9.450	12.305	13.816	6.639	24.889	7.149	12.237	24.959	12.898	11.230	18.511	25.378	9.796	45.869		
11	0.021009	6.005	9.140	13.308	8.263	8.659	11.344	12.691	6.124	22.803	6.542	11.268	22.931	11.940	10.273	17.117	23.245	9.068	41.645		
12	0.021009	5.709	8.714	12.680	7.888	8.234	10.825	12.085	5.846	21.677	6.217	10.746	21.841	11.420	9.762	16.362	22.096	8.674	39.368		
13	0.021009	5.462	8.359	12.155	7.575	7.881	10.391	11.579	5.613	20.737	5.947	10.310	20.934	10.985	9.337	15.731	21.139	8.345	37.471		
14	0.021009	5.243	8.041	11.687	7.294	7.567	10.003	11.127	5.405	19.896	5.706	9.920	20.125	10.595	8.960	15.165	20.284	8.049	35.777		
15	0.021009	5.012	7.706	11.195	6.998	7.237	9.593	10.651	5.186	19.011	5.453	9.510	19.275	10.182	8.564	14.568	19.385	7.738	33.996		
16	0.021009	4.790	7.382	10.719	6.711	6.919	9.197	10.191	4.974	18.155	5.210	9.113	18.455	9.782	8.183	13.990	18.518	7.436	32.278		
17	0.021009	6.584	9.970	14.534	8.991	9.490	12.353	13.873	6.665	24.994	7.179	12.286	25.062	12.946	11.279	18.582	25.486	9.832	46.083		
18	0.021009	6.294	9.555	13.921	8.628	9.074	11.849	13.282	6.395	23.899	6.860	11.777	23.995	12.444	10.775	17.850	24.365	9.451	43.864		
19	0.021009	5.926	9.028	13.142	8.164	8.546	11.207	12.531	6.051	22.506	6.456	11.131	22.643	11.803	10.138	16.918	22.941	8.964	41.044		
20	0.021009	5.419	8.296	12.063	7.519	7.819	10.315	11.490	5.572	20.572	5.899	10.233	20.775	10.908	9.263	15.620	20.971	8.287	37.138		
21	0.021009	5.185	7.957	11.564	7.220	7.484	9.900	11.007	5.350	19.674	5.643	9.817	19.912	10.491	8.860	15.016	20.059	7.971	35.330		
22	0.021009	5.022	7.720	11.215	7.010	7.251	9.611	10.671	5.195	19.048	5.464	9.527	19.311	10.200	8.580	14.594	19.423	7.751	34.071		

Table 7 TMR for Scottish Government 1GW SIL Individual Turbine – Note red denotes the SIL limit is NOT met



WTG No	PSV (nm)	With Background Noise										Without Background Noise									
		Standard EKA TMR	Siemens TMR	Senvion TMR	Vestas TMR	GE TMR	Nordex TMR	Enercon TMR	Gamesa TMR	SG155 TMR	Standard EKA TMR	Siemens TMR	Senvion TMR	Vestas TMR	GE TMR	Nordex TMR	Enercon TMR	Gamesa TMR	SG155 TMR		
1	0.013278	3.927	5.967	8.692	5.390	5.662	7.401	8.292	3.994	14.914	4.281	7.355	14.980	7.777	6.722	11.154	15.204	5.907	27.337		
2	0.013278	3.753	5.717	8.322	5.170	5.412	7.096	7.936	3.831	14.253	4.089	7.048	14.339	7.473	6.421	10.712	14.529	5.676	26.000		
3	0.013278	3.606	5.504	8.009	4.983	5.201	6.837	7.633	3.693	13.692	3.927	6.788	13.796	7.214	6.166	10.335	13.956	5.479	24.864		
4	0.013278	4.035	6.121	8.919	5.525	5.817	7.588	8.511	4.095	15.321	4.399	7.544	15.376	7.964	6.909	11.426	15.620	6.048	28.161		
5	0.013278	3.865	5.878	8.560	5.311	5.573	7.292	8.165	3.936	14.678	4.212	7.246	14.751	7.669	6.615	10.997	14.963	5.824	26.860		
6	0.013278	3.701	5.641	8.211	5.103	5.337	7.004	7.828	3.782	14.054	4.031	6.956	14.146	7.381	6.330	10.578	14.326	5.606	25.596		
7	0.013278	3.529	5.394	7.846	4.885	5.091	6.703	7.476	3.620	13.400	3.843	6.652	13.514	7.079	6.034	10.140	13.659	5.377	24.275		
8	0.013278	3.336	5.115	7.435	4.639	4.815	6.362	7.079	3.438	12.662	3.631	6.310	12.803	6.736	5.702	9.643	12.908	5.118	22.786		
9	0.013278	3.198	4.915	7.140	4.462	4.618	6.117	6.794	3.307	12.132	3.480	6.065	12.294	6.490	5.465	9.286	12.371	4.932	21.721		
10	0.013278	4.143	6.276	9.149	5.661	5.973	7.777	8.732	4.196	15.730	4.518	7.734	15.775	8.152	7.097	11.699	16.040	6.191	28.990		
11	0.013278	3.795	5.777	8.411	5.223	5.472	7.170	8.021	3.871	14.412	4.135	7.122	14.493	7.546	6.493	10.818	14.691	5.731	26.321		
12	0.013278	3.608	5.507	8.014	4.985	5.204	6.841	7.638	3.695	13.700	3.929	6.792	13.804	7.218	6.170	10.341	13.965	5.482	24.881		
13	0.013278	3.452	5.283	7.682	4.787	4.981	6.567	7.318	3.548	13.106	3.759	6.516	13.231	6.943	5.901	9.942	13.360	5.274	23.682		
14	0.013278	3.314	5.082	7.387	4.610	4.783	6.322	7.032	3.416	12.575	3.606	6.270	12.720	6.696	5.663	9.585	12.820	5.087	22.612		
15	0.013278	3.168	4.870	7.075	4.423	4.574	6.063	6.732	3.278	12.015	3.447	6.010	12.182	6.435	5.412	9.207	12.252	4.890	21.486		
16	0.013278	3.028	4.666	6.774	4.241	4.373	5.813	6.441	3.143	11.474	3.293	5.760	11.664	6.182	5.172	8.842	11.704	4.699	20.400		
17	0.013278	4.161	6.301	9.186	5.683	5.998	7.808	8.768	4.212	15.797	4.538	7.765	15.840	8.182	7.128	11.744	16.108	6.214	29.125		
18	0.013278	3.978	6.039	8.798	5.453	5.735	7.489	8.395	4.042	15.105	4.336	7.443	15.165	7.865	6.810	11.282	15.399	5.973	27.723		
19	0.013278	3.746	5.706	8.306	5.160	5.401	7.083	7.920	3.824	14.224	4.081	7.035	14.311	7.460	6.407	10.692	14.499	5.666	25.941		
20	0.013278	3.425	5.243	7.624	4.752	4.942	6.519	7.262	3.522	13.002	3.729	6.468	13.130	6.894	5.854	9.872	13.254	5.237	23.472		
21	0.013278	3.277	5.029	7.309	4.563	4.730	6.257	6.957	3.382	12.435	3.566	6.205	12.585	6.631	5.600	9.490	12.678	5.038	22.329		
22	0.013278	3.174	4.879	7.088	4.431	4.583	6.074	6.744	3.283	12.039	3.453	6.021	12.205	6.446	5.423	9.223	12.276	4.899	21.534		

Table 8 TMR for Scottish Government 2.5GW SIL Individual Turbine – Note red denotes the SIL limit is NOT met

6.2. Queue Scenario Results

6.1. Mitigation

As can be seen in Table 7 and Table 8 all turbines are above the Turbine Mitigation Ratio, which would indicate that no mitigation would be required should either a 1GW or 2.5GW SIL be adopted.

6.2.1. Scenario 1 – All wind farms included except Faw Side

Wind Farm	Status	Manufacturer	Synthetic Model	SIL 1.0 GW		SIL 2.0 GW		SIL 2.5 GW	
				Amplitude (nm)	Cumulative (nm)	Amplitude (nm)	Cumulative (nm)	Amplitude (nm)	Cumulative (nm)
Land SE of Scotston Bank Farm	Operational	unknown	GE	0.000164	0.207559	0.000164	0.207559	0.000164	0.207559
Little Hartfell	Approved	Nordex	Nordex	0.059846	0.216014	0.042317	0.211829	0.037850	0.210982
Faw Side	In Planning	unknown	Vestas		0.216014		0.211829		0.210982
Little Hartfell 2nd Sub	In Planning	Nordex	Nordex	0.059846	0.224151	0.042317	0.216014	0.037850	0.214350
Scoop Hill	In Planning	unknown	Vestas	0.171237	0.282074	0.121083	0.247636	0.108300	0.240156
Harestanes South	In Planning	unknown	GE	0.028465	0.283507	0.028465	0.249266	0.028465	0.241837
Daer	In Planning	unknown	GE	0.039895	0.286300	0.039895	0.252439	0.039895	0.245105
Cloch Forest	In Planning	unknown	Vestas	0.006445	0.286373	0.006445	0.252521	0.006445	0.245190
Greystone Knowe	In Planning	unknown	Vestas	0.006266	0.286441	0.006266	0.252599	0.006266	0.245270
Grayside	In Planning	unknown	GE	0.027374	0.287746	0.027374	0.254077	0.027374	0.246793
Callisterhall	In Planning	unknown	Vestas	0.050983	0.292228	0.038290	0.256946	0.034247	0.249158
Teviot	In Planning	unknown	Vestas	0.166147	0.336158	0.119516	0.283382	0.106899	0.271122
Scawd Law	In Planning	unknown	Vestas	0.009172	0.336283	0.009172	0.283531	0.009172	0.271277
Little Gala	In Planning	unknown	Vestas	0.003219	0.336298	0.003219	0.283549	0.003219	0.271296
Bloch	In Planning	unknown	GE	0.058260	0.341308	0.058260	0.289472	0.057218	0.277264
Millmoor Rig	In Planning	unknown	GE	0.017249	0.341743	0.017249	0.289986	0.017249	0.277800
Bodinglee	In Planning	unknown	Vestas	0.012636	0.341977	0.012636	0.290261	0.012636	0.278087
Rivox Farm	In Planning	unknown	Vestas	0.073345	0.349754	0.073345	0.299384	0.072140	0.287292
Westerkirk	S36 planning	unknown	Vestas	0.091148	0.361435	0.064451	0.306243	0.057647	0.293019
West Andershaw	S36 planning	unknown	Vestas	0.006489	0.361494	0.006489	0.306312	0.006489	0.293091
Brown Rig	S36 planning	unknown	Vestas	0.091530	0.372901	0.064722	0.313075	0.057889	0.298753
Oliver Forest	S36 planning	unknown	GE	0.038533	0.374887	0.038533	0.315437	0.038533	0.301227
Harestanes West	S36 planning	unknown	GE	0.022021	0.375533	0.022021	0.316205	0.022021	0.302031
Liddesdale	S36 planning	unknown	Vestas	0.059365	0.380196	0.059365	0.321729	0.059365	0.307810
Hearthstones	S36 planning	unknown	Vestas	0.055235	0.384188	0.040934	0.324323	0.036612	0.309980
M74 West		unknown	Vestas	0.012654	0.384396	0.012654	0.324570	0.012654	0.310238

Key	
	Site cannot be built within 0.336nm budget
	Site can be built within 0.336nm budget
	Site omitted from cumulative calculation as assumed unsuccessful in planning

Table 9 – Results for queue Scenario 1 – All wind farms included except Faw Side.



6.2.2. Scenario 2 – All wind farms included except Faw Side and Scoop Hill

Wind Farm	Status	Manufacturer	Synthetic Model	SIL 1.0 GW		SIL 2.0 GW		SIL 2.5 GW	
				Amplitude (nm)	Cumulative (nm)	Amplitude (nm)	Cumulative (nm)	Amplitude (nm)	Cumulative (nm)
Land SE of Scotston Bank Farm	Operational	unknown	GE	0.000164	0.207559	0.000164	0.207559	0.000164	0.207559
Little Hartfell	Approved	Nordex	Nordex	0.059846	0.216014	0.042317	0.211829	0.037850	0.210982
Faw Side	In Planning	unknown	Vestas		0.216014		0.211829		0.210982
Little Hartfell 2nd Sub	In Planning	Nordex	Nordex	0.059846	0.224151	0.042317	0.216014	0.037850	0.214350
Scoop Hill	In Planning	unknown	Vestas		0.224151		0.216014		0.214350
Harestanes South	In Planning	unknown	GE	0.028465	0.225951	0.028465	0.217882	0.028465	0.216232
Daer	In Planning	unknown	GE	0.039895	0.229446	0.039895	0.221504	0.039895	0.219881
Cloich Forest	In Planning	unknown	Vestas	0.006445	0.229537	0.006445	0.221598	0.006445	0.219976
Greystone Knowe	In Planning	unknown	Vestas	0.006266	0.229622	0.006266	0.221686	0.006266	0.220065
Grayside	In Planning	unknown	GE	0.027374	0.231248	0.027374	0.223370	0.027374	0.221761
Callisterhall	In Planning	unknown	Vestas	0.050983	0.236802	0.038290	0.226628	0.034247	0.224390
Teviot	In Planning	unknown	Vestas	0.166147	0.289275	0.119516	0.256212	0.106899	0.248552
Scawd Law	In Planning	unknown	Vestas	0.009172	0.289420	0.009172	0.256376	0.009172	0.248721
Liittle Gala	In Planning	unknown	Vestas	0.003219	0.289438	0.003219	0.256396	0.003219	0.248742
Bloch	In Planning	unknown	GE	0.058260	0.295243	0.058260	0.262932	0.057218	0.255238
Millmoor Rig	In Planning	unknown	GE	0.017249	0.295747	0.017249	0.263497	0.017249	0.255820
Bodinglee	In Planning	unknown	Vestas	0.012636	0.296017	0.012636	0.263800	0.012636	0.256132
Rivox Farm	In Planning	unknown	Vestas	0.073345	0.304968	0.073345	0.273806	0.072140	0.266097
Westerkirk	S36 planning	unknown	Vestas	0.091148	0.318297	0.064451	0.281290	0.057647	0.272270
West Andershaw	S36 planning	unknown	Vestas	0.006489	0.318364	0.006489	0.281364	0.006489	0.272348
Brown Rig	S36 planning	unknown	Vestas	0.091530	0.331260	0.064722	0.288712	0.057889	0.278432
Oliver Forest	S36 planning	unknown	GE	0.038533	0.333494	0.038533	0.291272	0.038533	0.281085
Harestanes West	S36 planning	unknown	GE	0.022021	0.334220	0.022021	0.292104	0.022021	0.281947
Liddesdale	S36 planning	unknown	Vestas	0.059365	0.339451	0.059365	0.298075	0.059365	0.288129
Hearthstanes	S36 planning	unknown	Vestas	0.055235	0.343916	0.040934	0.300872	0.036612	0.290445
M74 West		unknown	Vestas	0.012654	0.344148	0.012654	0.301138	0.012654	0.290721

Key	
■	Site cannot be built within 0.336nm budget
■	Site can be built within 0.336nm budget
■	Site omitted from cumulative calculation as assumed unsuccessful in planning

Table 10 – Results for queue Scenario 2 – All wind farms included except Faw Side and Scoop Hill.



6.2.3. Scenario 3 – All wind farms except Faw Side, Scoop Hill and Teviot

Wind Farm	Status	Manufacturer	Synthetic Model	SIL 1.0 GW		SIL 2.0 GW		SIL 2.5 GW	
				Amplitude (nm)	Cumulative (nm)	Amplitude (nm)	Cumulative (nm)	Amplitude (nm)	Cumulative (nm)
Land SE of Scotston Bank Farm	Operational	unknown	GE	0.000164	0.207559	0.000164	0.207559	0.000164	0.207559
Little Hartfell	Approved	Nordex	Nordex	0.059846	0.216014	0.042317	0.211829	0.037850	0.210982
Faw Side	In Planning	unknown	Vestas		0.216014		0.211829		0.210982
Little Hartfell 2nd Sub	In Planning	Nordex	Nordex	0.059846	0.224151	0.042317	0.216014	0.037850	0.214350
Scoop Hill	In Planning	unknown	Vestas		0.224151		0.216014		0.214350
Harestanes South	In Planning	unknown	GE	0.028465	0.225951	0.028465	0.217882	0.028465	0.216232
Daer	In Planning	unknown	GE	0.039895	0.229446	0.039895	0.221504	0.039895	0.219881
Cloich Forest	In Planning	unknown	Vestas	0.006445	0.229537	0.006445	0.221598	0.006445	0.219976
Greystone Knowe	In Planning	unknown	Vestas	0.006266	0.229622	0.006266	0.221686	0.006266	0.220065
Grayside	In Planning	unknown	GE	0.027374	0.231248	0.027374	0.223370	0.027374	0.221761
Callisterhall	In Planning	unknown	Vestas	0.050983	0.236802	0.038290	0.226628	0.034247	0.224390
Teviot	In Planning	unknown	Vestas		0.236802		0.226628		0.224390
Scawd Law	In Planning	unknown	Vestas	0.009172	0.236979	0.009172	0.226814	0.009172	0.224577
Liittle Gala	In Planning	unknown	Vestas	0.003219	0.237001	0.003219	0.226837	0.003219	0.224600
Bloch	In Planning	unknown	GE	0.058260	0.244057	0.058260	0.234199	0.057218	0.231774
Millmoor Rig	In Planning	unknown	GE	0.017249	0.244666	0.017249	0.234833	0.017249	0.232415
Bodinglee	In Planning	unknown	Vestas	0.012636	0.244992	0.012636	0.235173	0.012636	0.232758
Rivox Farm	In Planning	unknown	Vestas	0.073345	0.255735	0.073345	0.246345	0.072140	0.243681
Westerkirk	S36 planning	unknown	Vestas	0.091148	0.271493	0.064451	0.254636	0.057647	0.250407
West Andershaw	S36 planning	unknown	Vestas	0.006489	0.271570	0.006489	0.254719	0.006489	0.250491
Brown Rig	S36 planning	unknown	Vestas	0.091530	0.286580	0.064722	0.262813	0.057889	0.257093
Oliver Forest	S36 planning	unknown	GE	0.038533	0.289159	0.038533	0.265623	0.038533	0.259965
Harestanes West	S36 planning	unknown	GE	0.022021	0.289997	0.022021	0.266534	0.022021	0.260896
Liddesdale	S36 planning	unknown	Vestas	0.059365	0.296010	0.059365	0.273065	0.059365	0.267565
Hearthstanes	S36 planning	unknown	Vestas	0.055235	0.301120	0.040934	0.276116	0.036612	0.270058
M74 West		unknown	Vestas	0.012654	0.301385	0.012654	0.276406	0.012654	0.270354

Key	
■	Site cannot be built within 0.336nm budget
■	Site can be built within 0.336nm budget
■	Site omitted from cumulative calculation as assumed unsuccessful in planning

Table 11 – Results for queue Scenario 3 – All wind farms except Faw Side, Scoop Hill and Teviot.



6.2.4. Scenario 4 – All wind farms except Faw Side and those in Scoping

Wind Farm	Status	Manufacturer	Synthetic Model	SIL 1.0 GW		SIL 2.0 GW		SIL 2.5 GW	
				Amplitude (nm)	Cumulative (nm)	Amplitude (nm)	Cumulative (nm)	Amplitude (nm)	Cumulative (nm)
Land SE of Scotston Bank Farm	Operational	unknown	GE	0.000164	0.207559	0.000164	0.207559	0.000164	0.207559
Little Hartfell	Approved	Nordex	Nordex	0.059846	0.216014	0.042317	0.211829	0.037850	0.210982
Faw Side	In Planning	unknown	Vestas		0.216014		0.211829		0.210982
Little Hartfell 2nd Sub	In Planning	Nordex	Nordex	0.059846	0.224151	0.042317	0.216014	0.037850	0.214350
Scoop Hill	In Planning	unknown	Vestas	0.171237	0.282074	0.121083	0.247636	0.108300	0.240156
Harestanes South	In Planning	unknown	GE	0.028465	0.283507	0.028465	0.249266	0.028465	0.241837
Daer	In Planning	unknown	GE	0.039895	0.286300	0.039895	0.252439	0.039895	0.245105
Cloich Forest	In Planning	unknown	Vestas	0.006445	0.286373	0.006445	0.252521	0.006445	0.245190
Greystone Knowe	In Planning	unknown	Vestas	0.006266	0.286441	0.006266	0.252599	0.006266	0.245270
Grayside	In Planning	unknown	GE	0.027374	0.287746	0.027374	0.254077	0.027374	0.246793
Callisterhall	In Planning	unknown	Vestas	0.050983	0.292228	0.038290	0.256946	0.034247	0.249158
Teviot	In Planning	unknown	Vestas	0.166147	0.336158	0.119516	0.283382	0.106899	0.271122
Scawd Law	In Planning	unknown	Vestas	0.009172	0.336283	0.009172	0.283531	0.009172	0.271277
Liitle Gala	In Planning	unknown	Vestas	0.003219	0.336298	0.003219	0.283549	0.003219	0.271296
Bloch	In Planning	unknown	GE	0.058260	0.341308	0.058260	0.289472	0.057218	0.277264
Millmoor Rig	In Planning	unknown	GE	0.017249	0.341743	0.017249	0.289986	0.017249	0.277800
Bodinglee	In Planning	unknown	Vestas	0.012636	0.341977	0.012636	0.290261	0.012636	0.278087
Rivox Farm	In Planning	unknown	Vestas	0.073345	0.349754	0.073345	0.299384	0.072140	0.287292
Westerkirk	S36 planning	unknown	Vestas		0.349754		0.299384		0.287292
West Andershaw	S36 planning	unknown	Vestas		0.349754		0.299384		0.287292
Brown Rig	S36 planning	unknown	Vestas		0.349754		0.299384		0.287292
Oliver Forest	S36 planning	unknown	GE		0.349754		0.299384		0.287292
Harestanes West	S36 planning	unknown	GE		0.349754		0.299384		0.287292
Liddesdale	S36 planning	unknown	Vestas		0.349754		0.299384		0.287292
Hearthstanes	S36 planning	unknown	Vestas		0.349754		0.299384		0.287292
M74 West		unknown	Vestas	0.012654	0.349982	0.012654	0.299652	0.012654	0.287571

Key	
 	Site cannot be built within 0.336nm budget
 	Site can be built within 0.336nm budget
 	Site omitted from cumulative calculation as assumed unsuccessful in planning

Table 12 – Results for queue Scenario 4 – All wind farms included except Faw Side and those in Scoping.



6.2.1. Scenario 5 – All wind farms included

Wind Farm	Status	Manufacturer	Synthetic Model	SIL 1.0 GW		SIL 2.0 GW		SIL 2.5 GW	
				Amplitude (nm)	Cumulative (nm)	Amplitude (nm)	Cumulative (nm)	Amplitude (nm)	Cumulative (nm)
Land SE of Scotston Bank Farm	Operational	unknown	GE	0.000164	0.207559	0.000164	0.207559	0.000164	0.207559
Little Hartfell	Approved	Nordex	Nordex	0.059846	0.216014	0.042317	0.211829	0.037850	0.210982
Faw Side	In Planning	unknown	Vestas	0.148296	0.262019	0.104861	0.236363	0.093791	0.230890
Little Hartfell 2nd Sub	In Planning	Nordex	Nordex	0.059846	0.268766	0.042317	0.240121	0.037850	0.233971
Scoop Hill	In Planning	unknown	Vestas	0.171237	0.318681	0.121083	0.268922	0.108300	0.257821
Harestanes South	In Planning	unknown	GE	0.028465	0.319950	0.028465	0.270425	0.028465	0.259387
Daer	In Planning	unknown	GE	0.039895	0.322428	0.039895	0.273351	0.039895	0.262437
Cloich Forest	In Planning	unknown	Vestas	0.006445	0.322492	0.006445	0.273427	0.006445	0.262516
Greystone Knowe	In Planning	unknown	Vestas	0.006266	0.322553	0.006266	0.273499	0.006266	0.262591
Grayside	In Planning	unknown	GE	0.027374	0.323712	0.027374	0.274866	0.027374	0.264014
Callisterhall	In Planning	unknown	Vestas	0.050983	0.327702	0.038290	0.277520	0.034247	0.266226
Teviot	In Planning	unknown	Vestas	0.166147	0.367415	0.119516	0.302161	0.106899	0.286886
Scawd Law	In Planning	unknown	Vestas	0.009172	0.367530	0.009172	0.302300	0.009172	0.287033
Liitle Gala	In Planning	unknown	Vestas	0.003219	0.367544	0.003219	0.302318	0.003219	0.287051
Bloch	In Planning	unknown	GE	0.058260	0.372132	0.058260	0.307880	0.057218	0.292698
Millmoor Rig	In Planning	unknown	GE	0.017249	0.372532	0.017249	0.308363	0.017249	0.293206
Bodinglee	In Planning	unknown	Vestas	0.012636	0.372746	0.012636	0.308622	0.012636	0.293478
Rivox Farm	In Planning	unknown	Vestas	0.073345	0.379894	0.073345	0.317217	0.072140	0.302214
Westerkirk	S36 planning	unknown	Vestas	0.091148	0.390675	0.064451	0.323699	0.057647	0.307663
West Andershaw	S36 planning	unknown	Vestas	0.006489	0.390729	0.006489	0.323764	0.006489	0.307732
Brown Rig	S36 planning	unknown	Vestas	0.091530	0.401307	0.064722	0.330169	0.057889	0.313129
Oliver Forest	S36 planning	unknown	GE	0.038533	0.403152	0.038533	0.332410	0.038533	0.315491
Harestanes West	S36 planning	unknown	GE	0.022021	0.403753	0.022021	0.333139	0.022021	0.316259
Liddesdale	S36 planning	unknown	Vestas	0.059365	0.408094	0.059365	0.338387	0.059365	0.321782
Hearthstanes	S36 planning	unknown	Vestas	0.055235	0.411815	0.040934	0.340854	0.036612	0.323858
M74 West		unknown	Vestas	0.012654	0.412010	0.012654	0.341088	0.012654	0.324105

Key	
 	Site cannot be built within 0.336nm budget
 	Site can be built within 0.336nm budget
 	Site omitted from cumulative calculation as assumed unsuccessful in planning

Table 13 – Results for queue Scenario 5 – All wind farms included.

7. Discussion

7.1. Modelled Budget Requirements

The mathematical approach used in this document assesses the level of seismic budget required to build M74 West Wind Farm. The required seismic budget ranges from 0.017515 nm using the current MoD algorithm down to the predicted 0.002549 nm when using data from an SG155 with the background noise removed.

The budget range based on Phase 4 measurements including background is between 0.017074 nm for the no longer available Gamesa Machine and 0.007878 nm for the Senvion Machine.

The availability of budget will be subject to the ongoing work with Scottish Government, MoD and Eskdalemuir Working Group. It is envisaged that a significant amount of budget will be released. This budget is finite and there will likely be a significant demand for this precious resource. Submitting Planning the application sooner will reduce the risk associated with budget availability.

7.2. Modelled SIL Requirements

The Seismic Impact Levels for the M74 West Wind Farm have been assessed for a range of 1 GW to 2.5 GW deployment within the Eskdalemuir region. The 1 GW and 2.5 GW SIL limits represent a turbine SIL of $0.00836 \text{ nm} \cdot \text{MW}^{-0.5}$ and $0.00528 \text{ nm} \cdot \text{MW}^{-0.5}$ respectively. It should be noted that these figures might change during the SG and MoD signoff process. For the proposed 6.3 MW turbines at M74 West Wind turbine the permitted PSVs are 0.021009 nm and 0.013278 nm (again for 1 GW and 2.5 GW respectively).

All turbines at M74 West Wind Farm are above the Turbine Mitigation Ratio, which would indicate that no mitigation would be required should either a 1GW or 2.5GW SIL be adopted.

7.1. Queue Scenarios

Five queue scenarios were assessed based on the worst-case Phase 4 model (in this case the Vestas). SILs of 1.0, 2.0 and 2.5 GW were considered.

For a SIL of 1.0 GW, the only scenario where M74 West Wind Farm falls within the 0.336 nm budget is Scenario 3 (All wind farms except Faw Side, Scoop Hill and Teviot). For a SIL of 2.0 GW, M74 West Wind Farm falls within the budget for all scenarios except for Scenario 5 (All wind farms included). For a SIL of 2.5 GW, M74 West Wind Farm falls within the budget for all scenarios.

8. Conclusion

- M74 West Wind Farm, as proposed, represents 22 turbines, each with a power rating of 6.3 MW and has an average distance to the Eskdalemuir seismic array of ~43 km.
- The levels of Seismic Budget required by M74 West Wind Farm have been calculated using the best available science and most up to date data in the public domain.
- M74 West Wind Farm will likely be subject to proposed Seismic Impact Limits being assessed by the Scottish Government.
- The levels of Seismic Impact Limit have been calculated for all available data and Phase 4 measurements.
- The analysis shows that all turbine models could be built within the 1 GW or 2.5 GW Seismic Impact Limit under assessment by the EWG without mitigation.
- Due to the ~43 km distance from the array the M74 West Wind Farm is an efficient use of any available seismic budget.
- If background noise were removed the seismic budget requirement reduces substantially.
- Renewco Power would minimise seismic levels through performing candidate turbine, before and after measurements, should a process be available.
- Five queue scenarios with 1.0 GW, 2.0 GW or 2.5 GW SILs were considered.
- For a SIL of 1.0 GW, the only scenario where M74 West Wind Farm falls within the 0.336 nm budget is Scenario 3 (All wind farms except Faw Side, Scoop Hill and Teviot).
- For a SIL of 2.0 GW, M74 West Wind Farm falls within the budget for all scenarios except for Scenario 5 (All wind farms included).
- For a SIL of 2.5 GW, M74 West Wind Farm falls within the budget for all scenarios.



9. Reference Documents

Phase 1: 'Seismic Vibration produced by wind turbines in the Eskdalemuir region Release 2.0 of Substantial Research Project'

Phase 2: 'SGV_202_Tech_Report_v07'

Phase 3: 'SGV 203 Technical report v12.pdf'

Phase4 (Refinement): 'AIFCL-101-Phase4-Rev-v1:- Field audit of Selected sites within the EKA Consultation Zone to support Government Policy Decisions'

Phase 5 (Revision): 'AIFCL-101-Phase5-Rev-v11'

Onshore wind - policy statement refresh 2021: consultative draft

All publicly available documents can be downloaded [here](#)